

Certificate of Product Approval

Licensee:

Erse Kablo San. ve Tic. A.S.

Halil Rifat Pasa Mh. Yuzer Havuz Sk. No.:5-9, Sisli, Istanbul, Turkey

Factory:

Ortaköy Sanayi Bölgesi Elif Sokak No:12 Selimpaşa - Silivri, Istanbul, Turkey

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

STANDARD 60. Additionally tested to BS 6387:2013 Categories C, W & Z.

Materials:

Insulation EI 2, Sheath LTS 3

Brand Name:

ERVITAL FIRE SAFE GOLD CABLE

Origin Mark:

ERSE KABLO

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of BASEC Group Ltd

Date: 13/10/2025

Date of original issue: 13/10/2025

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 1 of 2



Expiry date:
30/06/2028

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size - sqmm	Max Nominal Size - sqmm
2	N/A	Class 1	2	1	1
2	N/A	Class 1 & 2	2	1.5	2.5
2	N/A	Class 1 & 2	3	1.5	2.5
2	N/A	Class 1 & 2	4	1.5	2.5
2	N/A	Class 2	2	4	4
2	N/A	Class 2	3	4	4
2	N/A	Class 2	4	4	4

Signed for and on behalf of BASEC Group Ltd

Date: 13/10/2025

Date of original issue: 13/10/2025

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No.13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 2 of 2



Expiry date:
30/06/2028