

Certificate of Product Approval

Erse Kablo Sanayi Ticaret A.S.

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1469a	05	Halil Rifat Pasa Mh. Yuzer Havuz Sk No. 5-9 Sisli 34384 Istanbul Turkiye

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS (see appendix for details)
ERVITAL FIRE SAFE GOLD CABLE	SD024 incorporating the following standards: BS 7629-1:2015+A1:2019 (Standard 60) BS 6387:2013 (Category CWZ) BS 5839-1:2013 (Clause 26.2d Standard) EN 50200:2015 (Class PH120) EN 50200:2015 Annex E BS EN 60754-2:2014+A1:2020
Fire Resistant Cables	

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.



Signed for BRE Global Ltd

Obada Piracha

Senior Certification Manager

07 September 2026

Date of Issue

01 May 2018

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



Appendix to Certificate No: 1469a

ISSUE

05

Erse Kablo Sanayi Ticaret A.S.

Product name					LPCB Ref. No.	
ERVITAL FIRE SAFE GOLD CABLE					1469a/01	
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7629-1 (See note 3)	BS 6387	EN 50200	BS 5839-1 Clause 26.2d (See note 4)	BS EN 60754-2
1.0 ⁽¹⁾	2	STANDARD 60	CWZ	PH120	Standard	Complies
1.5 ^(1,2)	2, 3 & 4	STANDARD 60	CWZ	PH120	Standard	Complies
2.5 ^(1,2)	2, 3 & 4	STANDARD 60	CWZ	PH120	Standard	Complies
4.0 ⁽²⁾	2, 3 & 4	STANDARD 60	CWZ	PH120	Standard	Complies

Uo/U 300/500V

Notes:

- Solid conductor only.
- Stranded conductor only.
- In meeting the requirements of BS 7629-1:2015 + A1:2019 Standard 60, the ERVITAL FIRE SAFE GOLD CABLE listed met the requirements for smoke density to BS EN 61034-2:2005 + A2:2020 and achieved less than 0.5% HCl for the outer covering, binding tape & insulation when tested in accordance with BS EN 60754-1 + A1:2020 and in addition also met the fire resistance requirements in BS 6387:2013 Categories CWZ.
- The ERVITAL FIRE SAFE GOLD CABLE listed conform to BS 7629-1:2015 + A1:2019 Standard 60, met Class PH120 when tested in accordance with EN 50200:2015 and met the 30 minutes duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2d of BS 5839-1:2013.

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Obada Aléev

Obada Piracha

07 September 2026

Signed for

Senior Certification Manager

Date of Issue

01 May 2018

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

