

Certificate of Product Approval

Certificate Number: 1469a

Issue: 04

ERSE KABLO SANAYI TICARET A.S.

Halil Rifat Pasa Mh.
Yuzer Havuz Sk
No. 5-9 Sisli
34384 Istanbul
Turkiye



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
ERVITAL FIRE SAFE GOLD CABLE

Standard(s) (see Appendix for details)

BS 7629-1:2015 (Standard 60)
BS 6387:2013 (Category CWZ)
BS 5839-1:2013 (Clause 26.2d Standard)
EN 50200:2015 (Class PH120)
EN 50200:2015 Annex E
EN 60754-2:2014
EN 60332-3-22:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Certification Scheme Manager

5 January 2021

Date of Issue

1 May 2018

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1469a ERSE KABLO SANAYI TICARET A.S.

Issue: 04

Product name								LPCB Ref. No.
ERVITAL FIRE SAFE GOLD CABLE								1469a/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	EN 50200 Annex E	BS 5839-1 Clause 26.2d	EN 60754-2	EN 60332-3-22
1.0 ⁽¹⁾	2	STANDARD 60 ⁽³⁾	C, W, Z	Class PH120	30 min ⁽⁴⁾	Standard ⁽⁵⁾	Complies	Complies
1.5 ⁽¹⁾	2,3 & 4	STANDARD 60 ⁽³⁾	C, W, Z	Class PH120	30 min ⁽⁴⁾	Standard ⁽⁵⁾	Complies	Complies
2.5 ⁽¹⁾	2,3 & 4	STANDARD 60 ⁽³⁾	C, W, Z	Class PH120	30 min ⁽⁴⁾	Standard ⁽⁵⁾	Complies	Complies
4.0 ^(1, 2)	2,3 & 4	STANDARD 60 ⁽³⁾	C, W, Z	Class PH120	30 min ⁽⁴⁾	Standard ⁽⁵⁾	Complies	Complies

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. In meeting the requirements of BS 7629-1:2015 Standard 60, the ERVITAL FIRE SAFE GOLD CABLE listed met the requirements for smoke density to EN 61034-2:2005 and achieved less than 0.5%HCl for the outer covering, binding tape & insulation when tested in accordance with EN 60754-1 and in addition also met the fire resistance requirements in BS 6387:2013 Categories CWZ.
4. The duration of 30 min when tested in accordance with EN 50200:2015 Annex E is achieved by 15 min for the fire and mechanical shock phase and an additional 15 min for the fire, mechanical shock and water phase.
5. The ERVITAL FIRE SAFE GOLD CABLE listed conform to BS 7629-1:2015 Standard 60, met Class PH120 when tested in accordance with EN 50200:2015 and met the 30 min duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aléer

Signed for BRE Global Ltd.

Obada Piracha
Certification Scheme Manager

5 January 2021
Date of Issue

1 May 2018
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

