



Certificate of constancy of performance

0099/CPR/B85/0754

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

ERSE KABLO SANAYI VE TICARET A.S.

registered office HALIL RIFAT PASA MAHALLESİ YÜZER HAVUZ SOKAK NO:5-9
34384 ISTANBUL (Sisli - Turkey)

Certified performance **Reaction to Fire of power electric cables for general applications in construction Works.**

Harmonised Standard EN 50575:2014
EN 50575:2014/A1:2016

Designation SZ1-K (AS+)
Trade Mark ERSE
Reaction to Fire Class Cca-s1a,d1,a1

See annex for more information.

Production site ORTAKÖY SANAYİ BÖLGESİ, ELİF SOKAK NO:12
34592 ISTANBUL (Silivri - Turkey)

Certification scheme This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied.
This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2021-09-21
Last issued on 2024-09-21
Validity 2027-09-21

Rafael GARCÍA MEIRO
CEO



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com



Certificate of constancy of performance

0099/CPR/B85/0754

Annex to Certificate

Designation SZ1-K (AS+)
Trade Mark ERSE
Reaction to Fire Class Cca-s1a,d1,a1

Cross-sectional Range	Rated Voltage	Generic Power Cable Family
From 2x1,5 mm ² to 2x50 mm ² ; From 3x1,5 mm ² to 3x50 mm ² ; From 4x1,5 mm ² to 4x50 mm ² ; From 5x1,5 mm ² to 5x50 mm ² .	0,6/1 kV	Multicore sheathed (unarmoured)
1x16 mm ² ; 1x25 mm ² ; 1x35 mm ² ; 1x50 mm ² .	0,6/1 kV	Single core sheathed (unarmoured)

First issued on 2021-09-21
Last issued on 2024-09-21
Validity 2027-09-21



AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com